


Accepted Manuscript

Assessment of future renewable energy scenarios in South Korea based on costs, emissions and weather-driven hourly simulation

Minsun Park, Mark Barrett, Tiziano Gallo Cassarino



PII: S0960-1481(19)30767-0
DOI: 10.1016/j.renene.2019.05.094
Reference: RENE 11686
To appear in: *Renewable Energy*
Received Date: 22 November 2018
Accepted Date: 22 May 2019

Please cite this article as: Minsun Park, Mark Barrett, Tiziano Gallo Cassarino, Assessment of future renewable energy scenarios in South Korea based on costs, emissions and weather-driven hourly simulation, *Renewable Energy* (2019), doi: 10.1016/j.renene.2019.05.094

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

1 Assessment of future renewable energy scenarios in South Korea based 2 on costs, emissions and weather-driven hourly simulation

3
4 **Minsun Park¹, Mark Barrett² and Tiziano Gallo Cassarino^{2,*}**

5 ¹ Institute for Environmental Design and Engineering, Bartlett School of Environment, Energy and
6 Resources, University College London, London, UK

7 ² Energy Institute, University College London, London, UK

8 * Corresponding author: t.cassarino@ucl.ac.uk

9 10 Abstract

11 The energy policy released by the South Korean government in 2017 aims to gradually increase
12 renewable energy to 20% while reducing the number of nuclear and coal power plants by 2030. The
13 constant controversy over the feasibility of this policy – which arose soon after its release – led to a
14 number of studies focussed on the environmental, economic, political and social issues related to the
15 current policy. However, none of these investigated the hourly dynamics of renewable energy supply,
16 which is crucial to provide an accurate assessment of an energy policy and a technical evaluation of its
17 feasibility. In this study, we analyse four potential renewable energy scenarios for 2030: Business as
18 Usual, Strengthened Solar (i.e. the new energy policy), Strengthened Wind, and our Suggested Scenario.
19 Using a bottom-up energy system modelling approach, we simulated solar and wind power generation
20 at the hourly level, integrating weather data provided by the NASA MERRA-2 reanalysis database. In
21 addition to the feasibility of each scenario, evaluated using annual generation and capacity factors, we
22 also examined the environmental and cost impacts through a number of different measures. Our results
23 show that both the Strengthened Solar and Strengthened Wind scenarios fail to meet the CO₂ emission
24 target proposed by the government. From the economic point of view, our cost analysis demonstrates
25 that renewable energy is sustainable for either Strengthened scenarios and cost-effective in both the
26 short term and long term, despite the high capital cost. Instead, our suggested scenario proves to be the
27 optimal solution by meeting the CO₂ emission target and minimising costs. Therefore, our hourly
28 simulation provides crucial evidence to assess the new energy policy and to evaluate alternative
29 solutions for the future energy system of South Korea.

30 31 Highlights

- 32 • Hourly solar and wind power generation in South Korea is simulated using MERRA-2.
- 33 • The South Korean government's scenario will not be able to meet the 2030 CO₂ emission target.
- 34 • Additional reduction of coal power plants, as in our suggested scenario, is essential.
- 35 • High share of renewables is cheaper on an annual basis and cost-effective in the long-term.

36

37 Keywords

38 Weather data, hourly simulation, solar and wind power scenarios, CO₂ emissions, economic costs, South
39 Korea

40

41 1. Introduction

42 The South Korean government established its CO₂ emission reduction target as 37% of the Business as
43 Usual (BaU) scenario by 2030 [1], as part of South Korea's emission trading scheme (KETS) [2], after its
44 adoption of the Paris Agreement [3]. In 2017, the government established a policy aiming to transition
45 from the current energy supply to a low-carbon energy mix, in line with what the majority of developed
46 countries have implemented since the adoption of the Kyoto Protocol. In addition, fine dusts (PM_{2.5},
47 PM₁₀) have plagued South Korea since 2013, and public concern about fossil fuels – with coal being one
48 of the main sources of fine dust [4,5] – has consequently become stronger [6]. Therefore, the
49 government set the aim of reducing fine dust to at least 30% by 2022. Its mitigation action includes
50 closing down coal power plants that are 30 or more years old, as well as cancelling both new and less-
51 than-10%-complete construction projects of coal power plants [7]. Moreover, growing public awareness
52 of the danger of nuclear power plants since the 2011 Fukushima Daiichi nuclear disaster and the recent
53 earthquake near Wolsong nuclear power plant, led the government to launch a policy for phasing out all
54 nuclear power plants by 2050.

55 The 8th Basic Energy Supply and Demand Plan (ESDP) was released in 2017 by the Ministry of Trade,
56 Industry and Energy (MOTIE) to mitigate the above-mentioned social and environmental issues facing
57 South Korea. The plan aim is to gradually expand renewable energy to 20% by 2030 while reducing coal
58 and nuclear energy by 9.4% and 6.4%, respectively [8]. The largest reduction target has been set for the
59 power sector, i.e. 64.5 Mt less than the emissions in the BaU scenario (333 Mt) [9]. As a mitigation
60 action to meet the CO₂ target, the MOTIE announced the “Renewable Energy 3020” plan (RE3020) in
61 December 2017 [1]. This plan involves a 20% increase in power generation from renewable energy
62 sources by adding 30.8 GW of solar power and 16.5 GW of wind-generating capacity by 2030. This is,
63 respectively, six and ten times higher than current capacity. As of 2017, the installed capacity of solar
64 and wind power was 5.03 GW and 1.17 GW, respectively.

65 Recently, several studies raised concerns over different aspects of the new energy policy. Some of these
66 adopted an evidence-based perspective on the details of the transition from the environmental and
67 economic points of view [10]. The new energy policy has also been criticised in terms of greenhouse gas
68 emissions reduction and energy security through South Korean power market simulations [11]. Other
69 studies assessed the social and political aspects of the new energy policy, finding that the majority of the
70 public is favourable to it, despite having concerns about high electricity bills [12], and that political as
71 well as environmental preferences have a stronger influence on people judgement than scientific or
72 economic considerations [13].

73 Energy system modelling is widely used [14] to give guidance towards feasible or suggested energy
74 systems under different assumptions [15]. CO₂ emissions and financial impacts of potential renewable
75 energy scenarios for South Korea in either 2030 or 2050 have been assessed to provide insights to
76 policymakers on the current energy policy [11,12,16,17]. However, these studies analysed annual data,
77 while solar and wind power generation requires spatial as well as temporal high-resolution data to be

78 accurately simulated [18]. The Modern Era Retrospective-Analysis for Research and Applications
79 (MERRA) reanalysis database [19] has recently become widely used to simulate solar and wind power
80 generation. In particular, MERRA data has been used to analyse the variability of renewable power
81 supply across Europe [20], to enhance the planning of renewable energy sources [21], and to assess
82 cost, emissions reductions, and energy security of a wide range of energy scenarios [15].

83 With this study we investigate the potential power supply mix of South Korea for 2030 with an hourly
84 simulation of the power generation driven by weather data. To provide novel insights to policymakers,
85 emissions and economic costs are assessed for four different scenarios: Business as Usual (BaU),
86 Strengthened Solar (SS), Strengthened Wind (SW), and our Suggested Scenario (SU). SS represents the
87 8th ESDP, SW switches the share of solar and wind power of SS, whereas a new SU scenario is proposed
88 to meet the CO₂ emission reduction target and minimise the power generation costs.

89

90 2. Material and Methods

91 2.1. Simulation

92 The hourly power demand in 2030 was simulated by scaling up the national load curve of 2017, taken
93 from the Korean Power Exchange [22], to meet the projected annual sum described in the 8th ESDP. The
94 time series of solar power generation was calculated with the Global Solar Energy Estimator (GSEE)
95 library [23] using the latest (2015) MERRA-2 [19] top-of-atmosphere, ground-level global irradiance,
96 temperature at 2m, and solar time at inland grid points. Wind power generation was simulated using in-
97 house software (Ed Sharp's unpublished results, 2016), in which wind-speed (2m, 10m, and 50m height)
98 at grid points nearest to the actual wind farm locations, is extrapolated linearly at a turbine hub height
99 of 80m. Then, the power output is found by using an aggregated power curve of the turbine model
100 Nordex N80 2.5 MW [24]. Since wind and solar power were calculated for a single MW of installed
101 capacity, these values were multiplied by the future installed capacities to estimate the actual hourly
102 generation in each scenario. In the simulation, hourly demand is met by subtracting generation in the
103 following order: solar, wind, coal, nuclear, liquefied natural gas (LNG), oil, hydro, biomass and waste,
104 without any generation surplus. The simulated curves were used to: (i) assess the reliability of solar and
105 wind power generation, (ii) estimate the CO₂ emissions, and (iii) calculate the short-term (CAPEX, annual
106 cost) and long-term costs.

107

108 2.2. Scenarios

109 The scenarios for the power supply mix simulated in this study are four: Business as Usual (BaU),
110 Strengthened Solar (SS), Strengthened Wind (SW), and our Suggested Scenario (SU). To create the BaU
111 scenario shown in Figure 1, the fraction of power generation mix of 2017 was scaled by the power
112 demand projection of 2030, in which coal dominates with 45%, while solar and wind reach only 1.4% of
113 the total supply. This scenario was used as reference for the emission and economic analysis, as
114 previously done in [25]. The SS scenario was taken from the 8th ESDP, and therefore represents the
115 government's new policy, in which coal still provides most of the supply (36%), but solar and wind
116 power are increased to 17%. We created the SW scenario to investigate wind power potential by taking
117 the share of solar and wind from SS and simply swapping them. Finally, the SU scenario was created in a
118 second stage in response to the failure of the other scenarios to meet the emission reduction target.

119 This scenario was found by changing iteratively, with steps of 10%, the fractions of coal, solar, and wind
 120 power taken from the SS scenario. The iteration stopped at a ratio of 7.35:2.65 between solar and wind,
 121 achieving the exact CO₂ emission target with the following shares: coal 32.5%, nuclear 23.9%, LNG
 122 18.8%, solar 15.2% and wind 5.5%.




Figure 1. Supply mix for scenario Business as Usual (BaU), Strengthened Solar (SS), and Strengthened Wind (SW)

123

124 2.3. Assessment

125 The simulated power output under the RE3020 plan is compared with the solar and wind power
 126 generation amount in each scenario. In addition, the annual capacity factor for solar and wind power
 127 was calculated as the fraction of the simulated power output, divided by the maximum generation (or
 128 nameplate capacity) along one year:

$$129 \quad CF = \frac{\sum_{h=0}^{8760} P_h}{ci * 8760} \quad [1]$$

130 where P_h is the power generation in each hour h and ci is the installed capacity, which is multiplied by
 131 the number of hours in a year.

132 The CO₂ emission of each simulated power source are calculated using the CO₂ emission factor (Solar 48,
 133 Wind 11, Coal 820, Nuclear 490, LNG 12, and Oil 782 in g/kWh) from the Intergovernmental Panel on
 134 Climate Change (IPCC) [26]. The emission reductions in each scenario are then calculated against the
 135 emission in the BaU scenario.

136 CAPEX is calculated by multiplying its unit price (GBP/kW) in Table 1 to the additional capacity required
 137 in each scenario, as in Table 2, on top of the installed capacity in 2017.

138

	Solar	Wind	Coal	Nuclear	LNG
CAPEX (GBP/kW) [27]	1560	1820	5017	7150	1300
Fixed O&M (GBP/kW) [28]	10.1	58.5	40.3	132.6	13
Variable O&M (GBP/MWh) [16]	2.210	0	5.382	0	4.323

Fuel cost (GBP/MWh) [29]	0	0	61.78	4.75	86.49
Life cycle (years) [30]	25	25	30	40	30
Construction period (years) [27]	1	1	4	10	3

139

140

Table 1. Assumed cost and time parameters for each power source

141

(GW)	BaU	SS	SW	SU
Coal	6.94	0	0	0
LNG	0	0	0	0
Nuclear	4.73	0	0	0
Solar	0	45.36	19.72	61.94
Wind	0.47	24.44	50.97	23.81
Total	12.14	69.8	70.69	85.75

142

143

Table 2. New GW of installed capacity by scenario

144

145 Operation and maintenance (O&M) costs and fuel costs are annual expenditures. The capital cost is
 146 converted to the equivalent “annual CAPEX” by using the Capital Recovery Factor (CRF) and a discount
 147 rate d of 5.5% [31]:

148

$$Annual\ CAPEX = CAPEX * CRF = CAPEX * \left(d \frac{(1+d)^n}{(1+d)^n - 1} \right) \quad [2]$$

149 where n is the lifecycle. Costs in Korean Won (KRW) were converted to GBP using an exchange rate of
 150 1156.05 KRW/USD and then of 1.2975 USD/GBP. In addition to annualized CAPEX, OPEX and fuel cost,
 151 this study considered a fixed emission trading cost of 14.67 GBP/ton CO₂e [2], even though this cost
 152 changes hourly depending on the demand and supply.

153

154 2.4. Long-term costs

155 A stock model was built for finding the long term cost of each scenario, as well as the year in which their
 156 cumulative costs are surpassed by the BaU scenario. The period taken into account was 25 years after
 157 2030, i.e. the life cycle of a solar or wind farm. The required new installed capacity, without
 158 replacement, of wind and solar power for 2030 was gradually added from 2019 until 2029 using a
 159 constant rate of 10%. Replacement of the existing coal plants is 30% [32] of the scenario requirement,
 160 and 10% for nuclear power plant [33]. The construction period was set to 1 year for wind and solar
 161 farms, 4 years for the coal power plants, and 10 years for nuclear power plants [27]. To compare the
 162 capital cost with the operating expenses, the former is converted to the annuitized CAPEX as:

163

$$AC = \frac{(PV * d)}{1 - (1 + d)^{-n}} \quad [3]$$

164 where PV is the present value of CAPEX, d is the discount rate and n is the payback time. The annual
 165 decrease rate for CAPEX and O&M costs is applied at 5% and 2%, respectively, due to the learning rate
 166 of technologies. The annual increase rate for fuel cost is assumed to be 3% according to the forecast
 167 that the LNG price will rise [34]. The emission trading cost is assumed to rise 1% annually, reflecting the
 168 current trend [35].

169

170 3. Results and discussions

171 3.1. Solar and wind power generation simulation

172 For solar power, the normalised hourly average along the simulated year was 7.7 MW, with a standard
 173 deviation of 10.7 MW, and the maximum peak was 39.8 MW. The highest seasonal average was 9 MW
 174 in spring, and the lowest was 6.3 MW in winter. Summer did not show the highest values because the
 175 rainy season reduces solar irradiance. For wind power, the hourly average was 20.5 MW, with a
 176 standard deviation of 22 MW, and the maximum peak was 118 MW. Winter showed the highest average
 177 of 36.2 MW, while autumn the minimum with 13 MW (Figure 2).




Figure 2. Simulated hourly solar (top) and wind power (bottom) output using weather data from 2017

178

179 3.2. Solar and wind power variability

180 The solar and wind normalised power outputs were multiplied for the installed capacity in each scenario
 181 in order to quantify expected costs and CO₂ emissions. We selected a week in May as a representative
 182 period of low power demand and high solar and wind supply (Figure 3), and a week in December with
 183 the opposite situation (Figure 4). The “low demand” week shows demand values ranging between 58
 184 and 83 GW, with an average of 73 GW. In BaU, the supply of solar and wind power ranges from 2.5 GW
 185 to 4.9 GW (average 1.5 GW), which is around 2.5–5% of the power demand. Thus, both base and
 186 intermittent load power plants must operate at full capacity to meet demand. In SS, solar and wind
 187 supplied an average of 19 GW, with a peak of 59 GW. SW and SU reached a similar higher average

188 production of 23 GW and 22 GW, respectively; however, only SU was able to fully meet demand (on the
189 14th of May). The “high demand” week shows demand values ranging between 70 and 107 GW, with an
190 average of 90 GW. In BaU, the average wind and solar supply is 553 MW, with a peak of 3 GW, while in
191 SS the average is 7 GW with a peak of 35 GW. In contrast to Figure 3, SW shows a lower value than SS.
192 The average of solar and wind power is 6 GW and the peak is 24 GW. The suggested scenario still shows
193 the highest solar and wind output, with an average of 8 GW and a peak of 46 GW. The base load unit is
194 in full-load operation, while the intermediate load supply decreases slightly only during the peak of solar
195 and wind supply at noon. Other periods show the same trend of the intermediate and base load supply
196 as the BaU. Unlike the “low demand” week, solar and wind power could not meet demand alone,
197 therefore all energy sources must be in operation at all time. Overall, the highest non-dispatchable
198 supply is achieved during the day, and therefore an effective utilization of solar power can be useful to
199 meet peak demand. Being only focussed on one weather year, our analysis has a limited assessment on
200 the demand and, in particular, on wind and solar supply inter-annual fluctuations. Future improvements
201 can either include more historical weather years to take into account climate variability, or forecasts to
202 assess the impact of future heat waves or cold spells.




Figure 3. Week with low demand and high solar and wind supply in each scenario




Figure 4. Week with high demand and low solar and wind supply in each scenario

205 3.3. Reliability of solar and wind power generation

206 According to the 8th ESDP, represented in our analysis by SS, the power generation from solar and wind
 207 farms is expected to reach 118 TWh annually. However, the simulated power generation in SS achieved
 208 only 79 TWh, with solar and wind reaching about 66% and 69%, respectively, of the expected
 209 generation. Similarly, SW reached 78 TWh, in which solar power is around 71% and wind 64%. The
 210 difference between the expected and the calculated power generation is due to the capacity factors (CF)
 211 calculated from our simulation (solar 18%, wind 17%), which were lower than those described in the 8th
 212 ESDP (solar 27%, wind 25%). However, the simulated CF for solar is much more similar to the one
 213 provided by NREL (18.7%) [30] than to the South Korean government's value. Wind CF, instead, is lower
 214 than the one provided by NREL (25%) because our simulation included only existing wind farm positions,
 215 the large majority of which are on-shore, where the average wind speed is around 5 m/s, that is, 2 m/s
 216 less than the average speed on off-shore areas [36]. In order to meet the generation target for SS and
 217 SW, the former requires to install further 8.06 GW of capacity for wind power and 17.04 GW for solar
 218 power, whereas the latter needs 18.79 GW of capacity for wind power and 7.2 GW for solar power. This
 219 difference implies that there is a discrepancy between the installed capacity predicted in the RE3020
 220 plan and the power generation expected in the 8th ESDP.

221

222 3.4. CO₂ emission reduction

223 The CO₂ emissions calculated from our simulation for the BaU scenario is 332.34 Mt, very close to the
 224 quantity estimated by the South Korean government (333 Mt). SS and SW have almost the same
 225 emissions, that is, 278 and 276 Mt respectively (Table 3), and in both about 74% of the carbon dioxide is
 226 emitted from coal power generation; the second source is LNG, with about 23%, while the remaining
 227 sources account for just 3% (Figure 5). In all scenarios, coal power generation must be reduced to
 228 effectively limit CO₂ emissions. SS is projected to emit 1.5 million tonnes (1%) of CO₂ more than SW
 229 because the CO₂ emission factor of solar power is four times higher than that of wind power. Although
 230 the direct emission from solar power is zero, indirect emissions during the construction and supply chain
 231 are 48g/kWh [26].

232

(Mt)	BaU	SS	SW	SU
Coal	258.63	205.65	205.65	185.08
LNG	57.54	64	64	64
Nuclear	2.53	1.99	1.99	1.99
Solar	0.35	3.8	1.87	5.05
Wind	0.03	0.43	0.87	0.42
Oil	3.26	1.63	1.63	1.63
Total (A)	322.34	277.49	276	258.17
RE3020 Target (B)	258.17	258.17	258.17	258.17
Further reduction (A) - (B)	64.16	19.32	17.83	0


233

234

Table 3. CO₂ emissions (Mt) for each power source and scenario

235

236 Both SS and SW fail to satisfy the target set by the government in 2030, as SS would require an
 237 additional reduction of 19.32 Mt, slightly higher than for SW (17.83 Mt). These gaps are taken into
 238 account in the emission trading costs.



239

240

Figure 5. Annual CO₂ emissions (Mt) for each energy source and scenario

241 On the other hand, the suggested scenario achieves the CO₂ emission reduction target by reducing coal
 242 capacity by 10%, more than the other scenarios. Such difference reduces CO₂ emissions from 205.65 (as
 243 for SS and SW) to 185.08 Mt.

244

245 3.5. Economic costs

246 The total cost until 2030 for BaU is 41.18 billion GBP, split almost evenly between coal and nuclear
 247 power plants, while only 0.5% is allocated for wind power farms. SS is estimated to cost 68.34 billion
 248 GBP (60% solar, 40% wind), SW 73.24 billion GBP (20% solar, 80% wind), and SU 82.98 billion GBP (75%
 249 solar, 25% wind). Regarding the annual expenses, BaU is predicted to cost 11.34 billion GBP/a, with fuel
 250 cost rising from 19% to 51% of the total annual cost. SS is estimated to cost 10.4 billion GBP/a, whereas
 251 SW would cost about 11.5 billion GBP/a; SU, instead, is estimated to cost 9.7 billion GBP/a, saving 6.8%
 252 of the annual expenditure of SS. In all three scenarios, the annual CAPEX is the largest fraction, followed
 253 by fuel cost. In addition, BaU is estimated to incur in the highest emission trading cost, at 0.94 billion
 254 GBP/a. SS and SW are expected to cost around 27% of the BaU cost, as opposed to SU, which has no
 255 emission trading costs (Table 4).

	BaU	SS	SW	SU
Annual CAPEX	2.7	5.09	5.46	6.18
Fixed O&M	0.55	1.12	1.89	1.2
Variable O&M	0.29	0.22	0.16	0.17
Fuel cost	6.86	3.71	3.71	2.16
Emission trading cost	0.94	0.28	0.26	0
Total	11.34	10.42	11.48	9.71

256

257 Table 4. Annual costs (billion GBP/a) by scenario

258

259 The greatest cost-savings in SS, SW, and SU occur for fuel (in absolute numbers) and for emission trading
260 (in percentage), however they are balanced by an increased annual CAPEX. SU has the greatest
261 additional installation of solar and wind farms, thus the highest annual CAPEX and the lowest fuel cost,
262 and does not incur in the emission trading cost. These results, combined with CO₂ emissions, indicate
263 that decline of fuel consumption is essential for both environmental and economic gains. The higher fuel
264 consumption, the more CO₂ emissions, and the higher the expenditure on fuel cost and emission trading
265 cost.

266 In addition, costs for thermal power generation could be higher by taking into account intermittent
 267 operation. However, in our simulations coal-fired power generation is zero very rarely: only 0.6% of the
 268 hours in the simulated year for SS, 0.4% for SW, and 1% for SU. Therefore, as the impact of losses due to
 269 intermittent operation is very marginal, neither losses nor additional costs in coal-fired power
 270 generation are considered in this analysis. Differently from coal, LNG power generation is zero only
 271 during 14.5% of the simulation time for SS, 10.2% for SW, and 20% for SU. LNG power plants can be
 272 operated for peak load generation either through shutdown, or by keeping a minimum load. The latter
 273 method has some advantages over the former, as turning off and on again the plant can take from 30
 274 minutes to one hour[37] and requires more fuel as well. In addition, restarting the power plant degrades
 275 the gas/steam turbines and, therefore, increases the OPEX. As the LNG power plants in South Korea are
 276 meant to be used intermittently[38], the impact from shutdowns is already considered at the design




Figure 6. Annual cumulated cost projections after 2030 for each scenario.

277 stage and in the project costs. Therefore, assuming minimum load when LNG power generation is zero
 278 does not increase CAPEX and OPEX, but only fuel costs. In order to calculate the additional fuel
 279 consumption, we can assume that the output during minimum load is 8% of total power generation,
 280 because during this operation only the gas turbine is used, at around 20% of total capacity, and it
 281 contributes to 40% of the power generation in a LNG combined cycle power plant[39]. We found that
 282 the increase of annual power generation due to minimum load operation is only 3.7% for SS, 2.6% for
 283 SW, and 5.3% for SU (calculated as the number of hours at minimum load multiplied by the minimum
 284 load). As the fuel cost accounts for 35% of the total costs, the impact of the minimum load on the total
 285 generation costs would be 1.3% for SS, 0.9 for SW, and 1.85% for SU. For this reason, we conclude that
 286 the impact of intermittent operation for LNG is negligible and can therefore be omitted from our
 287 analysis.

288 Regarding long-term cumulative costs from 2030 to 2055 (Figure 6), BaU initial cost in 2017 starts at
 289 5.98 Billion GBP, SS and SW at 10.2 and 11.47 billion GBP, respectively, while SU has the highest
 290 expenditure of 13 billion GBP. Based on these cumulated annuitized CAPEX during the construction
 291 period, the remaining annuitized CAPEX and the annual cost is added annually. The BaU cost rapidly
 292 increases compared to the other scenarios because of the higher portion of fuel cost, which has the

293 highest increase rate. As a result, the total cost of BaU exceeds SS in 2046 at 337 billion GBP, SU in 2046
294 at 350 billion GBP, and SW in 2051 at 443 billion GBP. Moreover, the total cost of SU becomes lower
295 than that of SS after 2048. Therefore, SS and SU are more economical than BaU after 16 years operation,
296 and SU is the cheapest after 18, thus reversing the order compared to the starting year. BaU reaches the
297 highest outgoing with 531.61 billion GBP, followed by SW with 486.91 billion GBP, then SS at 435.35
298 billion GBP, and finally SU with 413.63 billion GBP.

299

300 This analysis indicates that a high share of renewable energy, as represented by the SU scenario, is the
301 most cost-effective in the long term, while conventional energy sources seem economical only for the
302 initial investment in the short term. When considered as annual expenses, solar and wind energy
303 sources are cheaper than conventional energy because they do not consume fuel. Therefore,
304 considering CO₂ emissions as well, renewable energy is cost-effective and sustainable in both the short
305 term and long term.

306

307 4. Conclusion

308 This study simulates hourly solar and wind power supply using weather data provided by MERRA-2, with
309 the aim to investigate the solar and wind power generation potential of South Korea. The results were
310 used to assess the environmental and economic cost of four scenarios: Business as Usual, Strengthened
311 Solar (from the 8th ESDP), Strengthened Wind, and our Suggested Scenario, which meets the CO₂
312 emission target and achieves the minimum costs in the long term.

313 Our simulation indicates that solar power shows the highest output in spring, not summer, because the
314 latter is affected by heavy rain periods, while wind power generates the highest output in winter. During
315 one day of the “low demand” week in May, renewable supply was able to fully meet the power demand.
316 December is the season with the highest demand and the lowest renewable power supply; therefore,
317 the other sources need to be in full-load operation to meet demand. In order to maximize the utilization
318 of solar and wind power, the design of the power mix should consider the influence of weather
319 conditions on non-dispatchable energy sources. Hence, hourly simulations driven by climate data are
320 essential. From our results, power generation in SS did not achieve the target generation in the 8th ESDP,
321 therefore, additional installation of solar and wind farms should be required. The advance of technology
322 could improve the efficiency of solar and wind power generation in 2030. However, the capacity factor
323 of both sources depends on weather conditions. In addition, the installed capacity for on-shore wind
324 power is limited by geographical constraints and social acceptability issues. Being characterised by a
325 larger share of renewable energy and low fuel costs, SU is more capital intensive, but cheaper in the
326 long term, than the other scenarios. Given the current trend of increasing fuel prices, this analysis
327 should be considered conservative, thus our suggested renewable energy scenario could eventually
328 become cheaper than SS and SW earlier than expected. Moreover, considering the additional emission
329 trading cost, investing in sustainable resources, such as solar and wind, is economically beneficial both in
330 the short and in the long term. From the environmental point of view, SW is less polluting than SS, as
331 the CO₂ emission factor of solar power is around four times higher than wind power. However, it is more
332 expensive than SS due to the high CAPEX and OPEX of wind power. Since the difference in CO₂ emissions
333 between SS and SW is only 1%, SS seems to be a better solution for South Korea. Nevertheless, neither

334 SS nor SW could meet the CO₂ emission target in 2030. This analysis indicates that the 8th ESDP could
335 not meet the CO₂ reduction target without an additional reduction of coal power generation, since coal
336 is the biggest supply source. Therefore, only our suggested scenario SU achieved the national target
337 reduction for 2030, without causing additional costs due to the emission trading scheme launched in
338 2015.

339 The current analysis has some limitations that could be improved in future work. Weather data spans
340 only one year, thus excluding inter-annual variability. Considering climate change, which has manifested
341 especially in a hot summer and cold winter in 2017, we can expect different solar and wind power
342 generation, as well as a change in seasonal power demand. Wind power simulation considered only the
343 location of existing on-shore wind farms. However, since there is high potential for off-shore farms,
344 these could be included to improve the simulation. A possible extension of this work could include an
345 analysis of heat demand and supply to increase the comprehensiveness of the results. Finally, different
346 cost parameters could be applied to assess the range of expenses of each scenario. In particular, as
347 renewable energy technologies develop and mature rapidly, the CAPEX and O&M costs will drop.

348 Energy system modelling plays a crucial role in providing insights to policymakers to build effective
349 energy policies. A hourly simulation of wind and solar power dynamics, as the one presented in our
350 study, is essential to assess the potential role of renewable energy in future scenarios and, therefore, to
351 lead towards a transition to low-carbon and sustainable future energy system for South Korea.

352

353 Funding

354 This research did not receive any specific grant from funding agencies in the public, commercial, or not-
355 for-profit sectors.

356

357 References

- 358 [1] Ministry of Trade Industry and Energy (MOTIE), 3020 Renewable Energy Plan, (2017).
359 [http://www.motie.go.kr/motiee/presse/press2/bbs/bbsView.do?bbs_seq_n=159996&bbs_cd_n](http://www.motie.go.kr/motiee/presse/press2/bbs/bbsView.do?bbs_seq_n=159996&bbs_cd_n=81)
360 [=81](http://www.motie.go.kr/motiee/presse/press2/bbs/bbsView.do?bbs_seq_n=159996&bbs_cd_n=81) (accessed July 16, 2018).
- 361 [2] International Carbon Action Partnership (ICAP), Korea Emissions Trading Scheme, (2016) 1–5.
362 [https://icapcarbonaction.com/en/?option=com_etsmap&task=export&format=pdf&layout=list&](https://icapcarbonaction.com/en/?option=com_etsmap&task=export&format=pdf&layout=list&systems%5B%5D=47)
363 [systems%5B%5D=47](https://icapcarbonaction.com/en/?option=com_etsmap&task=export&format=pdf&layout=list&systems%5B%5D=47).
- 364 [3] United Nations, Adoption of the Paris agreement, 2015. doi:FCCC/CP/2015/L.9.
- 365 [4] D. Kang, J.-E. Kim, Fine, ultrafine, and yellow dust: emerging health problems in Korea., *J. Korean*
366 *Med. Sci.* 29 (2014) 621–2. doi:10.3346/jkms.2014.29.5.621.
- 367 [5] Greenpeace, *Silent Killer: Fine Particulate Matter*, 2016.
- 368 [6] Yonhap News, “Fine dust” most searched keyword by S. Korean users in H1: Google, (2018).
369 <https://en.yna.co.kr/view/AEN20180702005700320> (accessed July 22, 2018).
- 370 [7] Ministry of Environment (South Korea), *Comprehensive measures for fine dust control*, (2017).
371 http://www.motie.go.kr/common/download.do?fid=bbs&bbs_cd_n=81&bbs_seq_n=159674&fil

- 372 e_seq_n=1 (accessed July 16, 2018).
- 373 [8] Ministry of Trade Industry and Energy (MOTIE), The 8th the Electricity Supply and Demand Plan
374 (ESPD), (2017). <https://www.kpx.or.kr/www/contents.do?key=92> (accessed July 16, 2018).
- 375 [9] Kansai Research Center/Institute for Global Environmental Strategies POSCO Research Institute,
376 Domestic Carbon pricing in Korea and Companies' Response, 2017.
- 377 [10] S. Hong, B.W. Brook, A nuclear- to-gas transition in South Korea: Is it environmentally friendly or
378 economically viable?, *Energy Policy*. 112 (2018) 67–73. doi:10.1016/J.ENPOL.2017.10.012.
- 379 [11] Y.H. Song, H.J. Kim, S.W. Kim, Y.G. Jin, Y.T. Yoon, How to find a reasonable energy transition
380 strategy in Korea?: Quantitative analysis based on power market simulation, *Energy Policy*. 119
381 (2018) 396–409. doi:10.1016/J.ENPOL.2018.05.002.
- 382 [12] J. Kim, S.Y. Park, J. Lee, Do people really want renewable energy? Who wants renewable energy?:
383 Discrete choice model of reference-dependent preference in South Korea, *Energy Policy*. 120
384 (2018) 761–770. doi:10.1016/J.ENPOL.2018.04.062.
- 385 [13] J.-B. Chung, E.-S. Kim, Public perception of energy transition in Korea: Nuclear power, climate
386 change, and party preference, *Energy Policy*. 116 (2018) 137–144.
387 doi:10.1016/J.ENPOL.2018.02.007.
- 388 [14] S. Pfenninger, A. Hawkes, J. Keirstead, Energy systems modeling for twenty-first century energy
389 challenges, *Renew. Sustain. Energy Rev.* (2014). doi:10.1016/j.rser.2014.02.003.
- 390 [15] S. Pfenninger, J. Keirstead, Renewables, nuclear, or fossil fuels? Scenarios for Great Britain's
391 power system considering costs, emissions and energy security, *Appl. Energy*. (2015).
392 doi:10.1016/j.apenergy.2015.04.102.
- 393 [16] N.B. Park, S.J. Yun, E.C. Jeon, An analysis of long-term scenarios for the transition to renewable
394 energy in the Korean electricity sector, *Energy Policy*. (2013). doi:10.1016/j.enpol.2012.09.021.
- 395 [17] C.Y. Lee, S.Y. Huh, Forecasting new and renewable energy supply through a bottom-up approach:
396 The case of South Korea, *Renew. Sustain. Energy Rev.* (2017). doi:10.1016/j.rser.2016.11.173.
- 397 [18] J.P. Deane, A. Chiodi, M. Gargiulo, B.P. Ó Gallachóir, Soft-linking of a power systems model to an
398 energy systems model, *Energy*. 42 (2012) 303–312. doi:10.1016/J.ENERGY.2012.03.052.
- 399 [19] M.M. Rienecker, M.J. Suarez, R. Gelaro, R. Todling, J. Bacmeister, E. Liu, M.G. Bosilovich, S.D.
400 Schubert, L. Takacs, G.K. Kim, S. Bloom, J. Chen, D. Collins, A. Conaty, A. Da Silva, W. Gu, J. Joiner,
401 R.D. Koster, R. Lucchesi, A. Molod, T. Owens, S. Pawson, P. Pegion, C.R. Redder, R. Reichle, F.R.
402 Robertson, A.G. Ruddick, M. Sienkiewicz, J. Woollen, MERRA: NASA's modern-era retrospective
403 analysis for research and applications, *J. Clim.* (2011). doi:10.1175/JCLI-D-11-00015.1.
- 404 [20] M. Huber, D. Dimkova, T. Hamacher, Integration of wind and solar power in Europe: Assessment
405 of flexibility requirements, *Energy*. (2014). doi:10.1016/j.energy.2014.02.109.
- 406 [21] H. Zhang, Y. Cao, Y. Zhang, V. Terzija, Quantitative synergy assessment of regional wind-solar
407 energy resources based on MERRA reanalysis data, *Appl. Energy*. (2018).
408 doi:10.1016/j.apenergy.2018.02.094.
- 409 [22] Korea Power Exchange, Power supply and demand status, (2018).
410 <http://www.kpx.or.kr/www/contents.do?key=223> (accessed April 23, 2018).

- 411 [23] S. Pfenninger, I. Staffell, Long-term patterns of European PV output using 30 years of validated
412 hourly reanalysis and satellite data, *Energy*. (2016). doi:10.1016/j.energy.2016.08.060.
- 413 [24] E. Sharp, P. Dodds, M. Barrett, C. Spataru, Evaluating the accuracy of CFSR reanalysis hourly wind
414 speed forecasts for the UK, using in situ measurements and geographical information, *Renew.*
415 *Energy*. (2015). doi:10.1016/j.renene.2014.12.025.
- 416 [25] V. Krey, Global energy-climate scenarios and models: a review, *Wiley Interdiscip. Rev. Energy*
417 *Environ.* 3 (2014) 363–383. doi:10.1002/wene.98.
- 418 [26] B. Thomas, F. Lew, H. Edgar, M. Alan, P. Daniel, R. Joyashree, S. Roberto, S. Steffen, S. Ralph, S.
419 Pete, W. Ryan, H. Gesine, J. David, de, N. Maarten, Annex III: Technology-specific cost and
420 performance parameters, 2014.
- 421 [27] U.S. Energy Information Administration (EIA), Updated Capital Cost Estimates for Utility Scale
422 Electricity Generating Plants, (2016).
423 <https://www.eia.gov/analysis/studies/powerplants/capitalcost/> (accessed July 7, 2018).
- 424 [28] R. Lacal Arantegui, A. Jaeger-Waldau, M. Vellei, B. Sigfusson, D. Magagna, M. Jakubcionis, M. del
425 M. Perez Fortes, S. Lazarou, J. Giuntoli, E. Weidner Ronnefeld, G. De Marco, A. Spisto, C.
426 Gutierrez Moles, ETRI 2014 - Energy Technology Reference Indicator projections for 2010-2050,
427 2014. doi:10.2790/057687.
- 428 [29] Korea Power Exchange, Electric Power statistics Information System - Fuel price, (2018).
429 <http://epsis.kpx.or.kr/epsisnew/selectEkmaFucUpfGrid.do?menuId=050101> (accessed July 5,
430 2018).
- 431 [30] National Renewable Energy Laboratory (NREL), 2017 Annual Technology Baseline, (2017).
432 <https://atb.nrel.gov/electricity/2017/index.html?t=in> (accessed July 6, 2018).
- 433 [31] Korea Development Institute (KDI) - Public and Private Infrastructure Investment Management
434 Center (PIMAC), A Study on General Guidelines for Pre-feasibility Study (5th Edition), 2008.
- 435 [32] E2 News, Older coal fired power plants, extended life by major operations, (2016).
436 <http://www.e2news.com/news/articleView.html?idxno=91465> (accessed November 17, 2018).
- 437 [33] World Nuclear Association, Nuclear Power in South Korea, (2018) 1. [http://www.world-](http://www.world-nuclear.org/information-library/country-profiles/countries-o-s/south-korea.aspx)
438 [nuclear.org/information-library/country-profiles/countries-o-s/south-korea.aspx](http://www.world-nuclear.org/information-library/country-profiles/countries-o-s/south-korea.aspx) (accessed
439 November 19, 2018).
- 440 [34] World Bank Group, Commodity Markets Outlook, 2018.
- 441 [35] Korea Exchange (KRX), Emission trading cost, Mark. Data. (2018).
442 <http://marketdata.krx.co.kr/mdi#> (accessed July 20, 2018).
- 443 [36] National Institute of Meteorological Sciences (NIMS), Rate of wind speed over 5m/s, Weather
444 Resour. Map. (2016). http://www.greenmap.go.kr/02_data/data01_5_1.do#2%231%235
445 (accessed July 17, 2018).
- 446 [37] Siemens, Flexibility Solutions, 2016.
- 447 [38] J. Wook, Korean LNG power plants in slump amid low unit price, high production cost, (2017).
- 448 [39] L. Balling, Flexible future for combined cycle, Erlangen, 2010.