

Substantial emission reductions from Chinese power plants after the introduction of ultra-low emissions standards

Ling Tang^{1,2}, Jiabao Qu^{3,4}, Zhifu Mi^{5*}, Xin Bo^{3,6*}, Xiangyu Chang⁷, Laura Diaz Anadon⁸, Shouyang Wang⁹, Xiaoda Xue², Shibe Li³, Xin Wang¹⁰, Xiaohong Zhao³

In 2014, China introduced an ultra-low emissions (ULE) standards policy for renovating coal-fired power-generating units to limit SO₂, NO_x and PM emissions to 35, 50 and 10 mg m⁻³, respectively. The ULE standard policy had ambitious levels (surpassing those of all other countries) and implementation timeline. We estimate emission reductions associated with the ULE policy by constructing a nationwide, unit-level, hourly-frequency emissions dataset using data from a continuous emission monitoring systems network covering 96-98% of Chinese thermal power capacity during 2014-2017. We find that between 2014 and 2017 China's annual power emissions of SO₂, NO_x and PM dropped by 65%, 60% and 72%, respectively. Our estimated emissions using actual monitoring data are 18-92% below other recent estimates. We detail the technologies used to meet the ULE standards and the determinants of compliance, underscoring the importance of *ex-post* evaluation and providing insights for other countries wishing to reduce their power emissions.

¹School of Economics and Management, Beijing University of Chemical Technology, Beijing 100029, China.

²School of Economics and Management, Beihang University, Beijing 100191, China. ³Appraisal Center for Environment and Engineering, Ministry of Environmental Protection, Beijing 100012, China. ⁴School of Environment Science and Technology, HeBei University of Science and Technology, Shijiazhuang Hebei 050018, China. ⁵The Bartlett School of Construction and Project Management, University College London, London, WC1E 7HB, UK. ⁶School of Energy and Environmental Engineering, University of Science and Technology, Beijing 100083, China. ⁷School of Management, Xi'an Jiaotong University, Xi'an Shaanxi 710049, China. ⁸Centre for Environment, Energy and Natural Resource Governance, Department of Land Economy, University of Cambridge, Cambridge CB3 9EP, UK. ⁹Academy of Mathematics and Systems Science, Chinese Academy of Sciences, Beijing 100190, China. ¹⁰China National Environmental Monitoring Center, Ministry of Environmental Protection, Beijing 100012, China. *e-mail: z.mi@ucl.ac.uk; boxin@acee.org.cn.

23 China is currently suffering from severe air pollution, with the highest country level
24 values globally for population-weighted annual average concentration of fine
25 particulate matter with an aerodynamic diameter of 2.5 μm or less ($\text{PM}_{2.5}$) ($53 \mu\text{g m}^{-3}$)¹⁻
26 ³ and number of deaths (0.85 million) attributable to $\text{PM}_{2.5}$ in 2017¹. Thermal power
27 plants combusting coal, oil, natural gas, biomass or other fuels are one of the major
28 contributors to ambient air pollution: between 2010 and 2017, they accounted for 16-
29 39%, 19-51% and 5-23% of Chinese anthropogenic emissions of SO_2 ⁴⁻¹⁰, NO_X ⁴⁻¹¹ and
30 total particulate matter (PM) or dust⁴⁻⁶, respectively, with ranges depending on the
31 estimation method and the time period covered. SO_2 and NO_X are essential precursor
32 gases for secondary $\text{PM}_{2.5}$ ¹², and PM contains a 46-53% mass fraction of primary $\text{PM}_{2.5}$ ⁵.
33

34 In 1991 China began imposing progressively lower limits on emission concentrations
35 at power plants (Supplementary Data 1), with the most ambitious regulation in terms
36 of maximum emission levels and timing for implementation: ultra-low emissions (ULE)
37 standards. The current standards (GB13223-2011) that are still valid now went into
38 effect on July 1, 2014, limiting SO_2 , NO_X and PM emissions from Chinese coal-fired
39 power plants to 100, 100 and 30 mg m^{-3} , respectively¹³. These levels are already low
40 relative to those in other large jurisdictions, such as the US (184, 135 and 20 mg m^{-3}
41 for SO_2 , NO_X and PM, respectively) and the EU (200, 200 and 30 mg m^{-3}). Nevertheless,
42 on September 12, 2014, China proposed introducing even tougher emission standards
43 that are equivalent to those of natural gas-fired units, i.e., ULE standards: 35, 50 and
44 10 mg m^{-3} for SO_2 , NO_X and PM, respectively^{14,15}. These stricter ULE standards cover
45 the full fleet of existing and future coal-fired power-generating units, requiring that at
46 least 580 million kW installed capacity of existing units (accounting for 71% of the
47 total in 2014) meet the ULE standards by 2020¹⁶, that new units meet the ULE standards
48 since 2015¹⁴, and that at least 80% of capacity (including both preexisting and new units)
49 achieve compliance by 2030¹⁷. The ULE standards policy would result in significant
50 abatement costs to both governments (particularly in monitoring power plants and
51 supporting subsidies)¹⁸ and power plant owners (in updating technologies, installing

52 and operating control equipment, shutting down inefficient units and building new
53 units)^{14,19,20}. However, the ULE policy was expected to substantially reduce Chinese
54 power emissions²¹, thereby leading to considerable social benefits in terms of
55 environmental improvement²², health co-benefits²³ and technological progress in
56 emission control²⁰.

57

58 This substantial increase in the policy stringency of the ULE policy on Chinese coal-
59 fired power emissions has raised the interests of researchers and policy makers^{5,20-22,24}.
60 However, most research to date has relied on *ex-ante* studies estimating how the
61 introduction of the ULE standards *may* affect power emissions based on assumptions
62 about what changes in emission concentrations may take place and when they would
63 occur²². There have been no *ex-post* studies based on actual measurements. Although
64 there are a handful of global or Chinese power plant emissions databases providing
65 information at a unit or plant level²⁵⁻³⁰, they do not involve actual measured data on
66 emission concentrations (which are the targets of the new, stricter ULE standards).

67

68 Here, we assess in a highly spatially and temporally disaggregated manner the
69 mitigating effects of the new ULE standards, even ahead of the compliance period, as
70 well as the technologies used for abatement and the factors associated with early
71 compliance. We develop and analyse a Chinese power emissions database, named the
72 China Emissions Accounts for Power plants (CEAP) (which we make available here:
73 <http://www.ieimodel.org/>). The CEAP database presents, organizes and analyses data
74 from China's continuous emission monitoring systems (CEMS) network
75 (<http://www.envsc.cn/>): the direct, actual, real-time measurements of emission
76 concentrations for a variety of air pollutants at power plant stacks nationwide (the right
77 targets of the ULE standards). We expand on the work of Karplus et al. (2018), which
78 used CEMS data for four provinces in China to study the changes in stack SO₂
79 concentration at coal-fired power plants associated with the GB13223-2011 standard.
80 The use of nationwide, detailed and continuous CEMS data provides a direct estimation

81 for emission factors and absolute emissions at high spatial (unit-specific) and temporal
82 (hourly-frequency) resolutions. This differentiates the CEAP database from other
83 power emissions databases²⁵⁻³⁰ that were based on average, invariable and outdated
84 (without *ex-post* measurements) emission factors (Supplementary Note 1). We conduct
85 a comprehensive uncertainty analysis and validate our estimates. We use the CEAP
86 dataset to conduct an analysis of overall, unit-specific, time-varying effects of the new
87 ULE standards on Chinese power emissions from 2014 to 2017. We compare our
88 estimates using actual measurements with previous estimates using average emission
89 factors and show that the previous methods significantly overestimated Chinese power
90 emissions for 2014-2017. Furthermore, we detail the mechanisms used to meet the ULE
91 standards and factors associated with a greater probability of early compliance. These
92 analyses not only highlight fuel-, region- and capacity-specific opportunities to further
93 reduce Chinese power emissions in the near future but also provide insights for
94 countries looking to reduce their power emissions.

95

96 **Early compliance with ultra-low emissions standards**

97 CEMS data suggest encouraging news about the systematic reductions in stack
98 concentrations at Chinese thermal power plants after the introduction of the ULE
99 standards in 2014. Figure 1 displays the geographic distribution, fuel type and operating
100 capacity of the 4,622 power plant stacks monitored by the CEMS network in 2017. The
101 corresponding information for 2014, 2015 and 2016 is presented in Supplementary
102 Figures 1, 2 and 3, respectively. From the histograms, a clear, continuous decline in
103 stack concentrations at Chinese thermal power plants can be observed from 2014 to
104 2017, with mean annual reductions of 33.34%, 28.29% and 38.06% for SO₂, NO_x and
105 PM, respectively (the non-red dashed lines of Figure 1). The overall compliance rates,
106 i.e., the percentages of total capacity decreasing the annual average concentrations of
107 SO₂, NO_x and PM below the respective ULE criteria (the samples on the left of the red
108 dashed lines in the histograms of Figure 1 and Supplementary Figures 1-3), increased
109 from 15.63%, 10.47% and 15.79% in 2014 to 74.54%, 70.64% and 87.50% in 2017,

110 respectively (Supplementary Data 2).

111

112 As the main ULE targets, the stack concentrations of Chinese coal-fired power plants
113 have substantially decreased since 2014, leading to an extensive early compliance at
114 the end of 2017. Figure 2 shows the daily distributions of stack SO₂, NO_x and PM
115 concentrations for different fuel types during 2014-2017. In general, a striking
116 downtrend in the coal-fired power emission concentrations can be observed, with
117 average monthly decreases of 2.82%, 2.79% and 3.65% for SO₂, NO_x and PM,
118 respectively, from 2014 to 2017 (the 2nd row in Figure 2). Crucially, these rates of
119 reduction suddenly increased in July 2014 (the deadline for implementing the
120 GB13223-2011 limits); specifically, they reached 10.97%, 11.43% and 3.54% for SO₂,
121 NO_x and PM, respectively. For the next two months, the rates of decrease in monthly
122 stack concentrations rapidly dropped to 0.69%, 3.20% and 2.29%, respectively, on
123 average. Nevertheless, after the introduction of the ULE standards in September 2014,
124 such declining trends persisted at steady monthly rates averaging 2.81%, 2.47% and
125 3.87% for SO₂, NO_x and PM, respectively, over the whole ULE period from November
126 2014 to December 2017. At the end of 2017, the mean SO₂, NO_x and PM concentrations
127 from Chinese coal-fired power plants hit 35.30, 52.00 and 5.70 mg m⁻³, respectively
128 (Supplementary Data 3). Overall, 72.30% of Chinese coal-fired capacity had achieved
129 early compliance with all three ULE emission limits by December 2017. Given that the
130 2030 target was to achieve compliance in 80% of coal-fired capacity¹⁷, it seems likely
131 that this target will be met ahead of schedule. Early compliance was encouraged by
132 provisions in the ULE regulations themselves^{16,32}: coal-fired power plants in China
133 have access to a wide range of financial incentives if they meet the ULE standards,
134 which can largely offset (and in many cases exceed) the costs of compliance
135 (Supplementary Note 2).

136

137 We find that Chinese coal-fired power plants reduced stack concentrations to meet the
138 ULE standards mainly through three mechanisms (Supplementary Note 2): renovating

139 preexisting traditional units for ULE (by installing and turning on pollution control
140 equipment and upgrading their removal efficiency), shutting down small inefficient
141 units and constructing new units with state of the art ULE control technology^{16,31,33}.
142 From 2014 to 2017, a total of 591.47 million kW of preexisting coal-fired capacity that
143 had been built before 2015 was renovated to meet the ULE standards (surpassing the
144 2020 target of 580 million kW¹⁶). Meanwhile, the combined installed capacity of small
145 coal-fired units below 300 MW was cut by 16.9 million kW. As a result, the stack
146 concentrations of preexisting units built before 2015 declined significantly, with mean
147 monthly decreases of 3.05%, 2.28% and 3.61% for SO₂, NO_x and PM, respectively,
148 from 2015 to 2017 (the blue lines in the insets of Figure 2). Since 2015, 96.07 million
149 kW of new coal-fired capacity has been built by the end of 2017 (which had to install
150 ULE technologies to achieve compliance according to the ULE regulation¹⁶), with stack
151 concentrations averaging 27.27, 47.70 and 6.27 mg m⁻³ for SO₂, NO_x and PM,
152 respectively (below the ULE standards; green lines).

153

154 By the end of 2017, nearly all coal-fired capacity in China had installed SO₂ control
155 equipment³⁴, and were running such systems on average 97.02% of the total operating
156 time between 2014 and 2016. Typical SO₂ control systems include limestone-gypsum
157 wet desulfurization (deployed in 84.40%, 86.85% and 87.71% of coal-fired capacity in
158 2014, 2015 and 2016, respectively), flue gas circulating fluidized bed desulfurization
159 (6.47%, 5.24% and 4.89%), seawater desulfurization (2.65%, 2.52% and 2.45%) and
160 ammonia absorption (0.76%, 0.88% and 0.84%). These methods have been technically
161 improved to achieve ultra-high removal efficiencies (even reaching 99.70%; Panel A in
162 Supplementary Data 4). These improvements contributed to 80.15% of Chinese coal-
163 fired capacity achieving early ULE compliance for SO₂ in December 2017
164 (Supplementary Data 3).

165

166 In reducing NO_x emissions, China has experienced considerable progress: the
167 installation of relevant control technologies increased from 13% of total coal-fired

168 capacity in 2010²⁵ to 98.40% in 2017³⁴. The most prevalent equipment used to reduce
169 NO_x emissions is flue gas denitrification technologies. One such technology, selective
170 catalytic reduction, was used in 80.49%, 88.19% and 88.67% of coal-fired capacity in
171 2014, 2015 and 2016, respectively. This equipment is not turned on as frequently as the
172 SO₂ control equipment: on average it was functioning during 94.22% of the total
173 operating time between 2014 and 2016. Relying to a large extent on these technologies,
174 which have removal efficiencies reaching 90.00% (Panel B in Supplementary Data 4),
175 75.63% of coal-fired capacity had met the ULE NO_x limit by the end of 2017
176 (Supplementary Data 3).

177

178 Control measures for PM were already prevalent in Chinese coal-fired power plants
179 before the ULE policy²⁵, and recent improvements have primarily focused on upgrading
180 the efficiency of existing equipment. For example, through technological improvements,
181 commonly used technologies, e.g., electrostatic dust removal technology (used in
182 77.30%, 69.08%, 68.40% and 65.90% of coal-fired capacity in 2014, 2015, 2016 and
183 2017, respectively), electrostatic-bag dust removal technology (13.70%, 22.24%, 23.20%
184 and 25.40%), and bag-type dust removal technology (9.00%, 8.68%, 8.40% and
185 8.70%)³⁴ that removed 99.75% of PM on average, ended up removing over 99.90%
186 (Panel C in Supplementary Data 4)¹⁵. With the largest penetration of control
187 technologies (100% in 2017)³⁴, the highest removal efficiencies (over 99.90%)¹⁵ and
188 the longest running time (representing 99.15% of the total operating time on average
189 during 2014-2016), the compliance rate for PM was the highest (90.17% in December
190 2017; Supplementary Data 3).

191

192 Non-coal thermal power plants also experienced general declines in stack
193 concentrations, in spite of the fact that they are not targeted by the ULE regulation (from
194 the 3rd to 5th rows in Figure 2; Supplementary Note 3). These reductions were largely
195 attributable to the age structure shift towards younger units with higher energy
196 efficiency and lower emission intensities: 29.63%, 25.70% and 25.08% of gas and oil-,

197 biomass- and other fuel-fired capacities, respectively, were built after 2014, compared
198 with 15.97% of coal-fired capacity. Overall, the stack concentrations across all fuel
199 types declined over the sampling period (the 1st row) at average monthly rates of 2.95%,
200 2.55% and 3.63% for SO₂, NO_x and PM, respectively (Supplementary Data 3).

201

202 **Mitigation effect of ultra-low emissions standards**

203 Figure 3 shows the calculated time-varying emission factors and total emissions of SO₂,
204 NO_x and PM from Chinese power plants between 2014 and 2017, revealing a
205 substantial mitigation effect of the ULE policy. The monthly emission factors of
206 Chinese power plants declined from 2014 to 2017 by 75.33%, 76.03% and 83.31% for
207 SO₂, NO_x and PM, respectively, for coal-fired units, by 69.20%, 25.06% and 64.90%
208 for biomass-fired units, and by 52.35%, 46.87% and 76.94% for gas-fired units (lines
209 in the left column). Although Chinese thermal power generation increased by 3.49%
210 every year from 2014 to 2017 (blue bars in the right column; right axis), the positive
211 effect on emissions was completely offset by the decline in emission factors. Therefore,
212 Chinese power emissions show a downward trend over the four years, decreasing from
213 2.21, 3.11 and 0.52 Mt in 2014 to 0.77, 1.26 and 0.14 Mt in 2017 by 1.44, 1.85 and 0.37
214 Mt (i.e., 65.03%, 59.50% and 72.37%) for SO₂, NO_x and PM, respectively (red lines in
215 the right column; left axis). We find that our estimates using actual emission
216 measurements are considerably (17.55-91.86%) lower than other previous estimates
217 that primarily depended on emission factors without considering the ULE effect
218 (datapoints in the right column; left axis).

219

220 Using the CEAP database, we analyse the factors associated with early ULE
221 compliance (determining early vs late compliers and identifying the top contributors to
222 the emission reductions). We focus on three determinants of compliance, fuel, region
223 and size, to explore the operational feasibility and technical viability of the ULE limits
224 and to highlight specific opportunities for future emission reductions. Figure 4 shows
225 the estimated reductions in SO₂, NO_x and PM emissions for power plants using

226 different fuel types, located in different regions and of different generating capacities
227 from 2014 to 2017, as well as the potential reductions from 2017 to 2020 under an
228 extreme scenario assuming that all power-generating units meet the ULE standards in
229 2020.

230

231 As for fuel type, coal-fired generators contributed the largest shares (89.27%, 95.37%
232 and 92.82%, respectively) to the reductions in SO₂, NO_x and PM emissions from
233 Chinese power plants between 2014 and 2017, whereas biomass-fired generators made
234 the smallest contributions (0.17%, 0.11% and 0.23%) (the top row in Figure 4). These
235 findings can be primarily explained by the proportion of total thermal power capacity
236 (averaging 92.79% for coal-fired units vs 0.17% for biomass-fired units during 2014-
237 2017; Supplementary Data 2) and the extent of emission mitigation (with annual coal-
238 fired SO₂, NO_x and PM emissions (the targets of the ULE regulation) declining by
239 64.06%, 62.64% and 73.11%, respectively, from 2014 to 2017, vs biomass-fired
240 emissions declining by 37.11%, 19.05% and 37.97%). Perhaps surprisingly, the annual
241 SO₂ and NO_x emissions from biomass- and other fuel-fired units increased from 2014
242 to 2015. The hidden reason for these trends might be the age structure shift towards
243 younger units (Supplementary Note 3), i.e., the emissions from newly built units offset
244 the emission reductions from preexisting units.

245

246 The power sector emissions from all six Chinese regions (as defined in Supplementary
247 Data 5) declined drastically from 2014 to 2017, with the eastern region contributing the
248 largest shares to nationwide emission reductions (27.67%, 28.69% and 35.13% for SO₂,
249 NO_x and PM, respectively), closely followed by the northern (23.22%, 20.28% and
250 18.90%) and central and southern regions (17.25%, 17.48% and 14.25%) (the middle
251 row in Figure 4). From 2014 to 2017, these three regions accounted for the largest
252 percentages of thermal power capacity (averaging 74.51% for 2014-2017;
253 Supplementary Data 2) and contributed 68.15%, 66.45% and 68.28% to the nationwide
254 reductions in SO₂, NO_x and PM power emissions, respectively. Furthermore, the

255 eastern, northern and central and southern regions faced the toughest policy stringency,
256 involving 21, 7 and 11, respectively, out of 47 key regions defined and prioritized by
257 the GB13223-2011 standards in terms of levels¹³ and having 3, 4 and 1, respectively,
258 out of 9 tight local emission standards (Supplementary Data 1). The ULE policy
259 prioritized East China over Central China in terms of timelines, followed by West
260 China¹⁶. Under considerable pressure, the eastern region made the greatest effort to
261 meet the standards (achieving the highest compliance rates of 92.51%, 88.29% and
262 96.15% of total thermal power capacity for SO₂, NO_x and PM, respectively, in 2017).
263 In comparison, the southwestern region, which had the fewest thermal power units
264 (representing 6.65% of the nationwide capacity on average between 2014 and 2017;
265 Supplementary Data 2) and the longest timeline¹⁶, contributed the least to nationwide
266 emission reductions (9.26%, 10.10% and 8.18% for SO₂, NO_x and PM, respectively).

267

268 The capacity-specific analysis reveals a clear shift in reduction contributions from
269 large-capacity units (representing a large fraction of total capacity) to small-capacity
270 units (dominated by super-polluting units) (the bottom row in Figure 4). The majority
271 of Chinese power-generating units were large-capacity units (with units larger than 300
272 MW representing 80.95% and 83.12% of total thermal power capacity and coal-fired
273 capacity, respectively, for 2014-2017; Supplementary Data 2). The ULE standards
274 prioritize key (high-emitting) coal-fired units¹⁶, such that large-capacity units above
275 300 MW emitting the largest shares of power emissions (63.26%, 60.79% and 62.02%
276 for SO₂, NO_x and PM, respectively, on average between 2014 and 2017) and dominated
277 by coal-fired units (representing 95.27% of large-capacity units in unit capacity
278 between 2014 and 2017; Supplementary Data 2) fell into the main ULE target.
279 Accordingly, large-capacity units achieved compliance faster than small-capacity units
280 (with the ULE compliance rates of 68.59% for thermal units larger than 300 MW vs
281 43.29% for thermal units smaller than 100 MW, in 2017) and became a large contributor
282 to power emission reductions (with units larger than 300 MW contributing 58.60%,
283 60.11% and 60.56% to total emission reductions for SO₂, NO_x and PM, respectively,

284 from 2014 to 2017). Nevertheless, retiring small-capacity units (with the combined
285 installed capacity of units smaller than 100 MW declining from 2014 to 2017 by 19.8
286 million kW) was also an efficient mechanism for abatement. These small-capacity units
287 were often super-polluting units that accounted for a small fraction of capacity
288 (representing 7.38% of total thermal power capacity during 2014-2017; Supplementary
289 Data 2) but generated disproportionately large quantities of emissions (representing
290 23.00%, 23.43% and 23.13% of total SO₂, NO_x and PM emissions, respectively).

291

292 We also assess fuel-, region- and capacity-specific opportunities for further reducing
293 Chinese power emissions by progressively enhancing ULE compliance (Supplementary
294 Note 4). From 2017 to 2020, the annual SO₂, NO_x and PM emissions are projected to
295 decline by 22.13%, 8.28% and 2.04%, respectively, if all coal-fired units meet the ULE
296 standards in 2020 and by 23.21%, 15.49% and 2.69%, respectively, if all thermal units
297 achieve compliance.

298

299 **Discussion**

300 We develop a Chinese power plant emissions database using CEMS data for 2014-2017
301 and conduct analysis of the nationwide, unit-specific, time-varying effects of the new
302 ULE standards. The findings of this study indicate the efficacy of the ULE standards:
303 it resulted in a systematic reduction in emission factors for all fuel types by 25-83% and
304 in absolute emissions by over 60%, underscoring the importance of *ex-post* evaluation.
305 We find an overall early compliance of coal-fired power plants that was encouraged by
306 significant financial incentives according to the ULE regulations: by the end of 2017,
307 the 2020 target for updates to preexisting units has been met and even surpassed, and
308 90% of the compliance 2030 target has been achieved. The dominant mechanisms of
309 early compliance included switching on and upgrading control equipment and shutting
310 down small super-polluting units. The early ULE compliers or large contributors to
311 emission reductions were the power-generating units burning coal, located in the
312 eastern region and on a large capacity scale, with each group representing a large

313 fraction of unit capacity and facing tough policy stringency in levels and timelines. We
314 highlight that a focus on coal-fired units (still with large room for improvement and the
315 largest proportion of total capacity), West China (with the longest timeframe) and small-
316 capacity units (dominated by super-polluting units) can further reduce annual SO₂, NO_x
317 and PM power emissions by 23%, 15% and 3%, respectively, from 2017 to 2020.

318

319 The CEAP database and *ex-post* measurements can be used to investigate air quality
320 improvements²² and health co-benefits³⁵ associated with the ULE standards and to
321 improve the modelling accuracy by offering nationwide, unit-based and high-frequency
322 power emission inventories³⁶. Actually, the Chinese CEMS network covers both air and
323 water pollutants from different industrial sectors (encompassing over 30,000 pollution-
324 emitting sources), with air pollutants from the power sector just as one small part. We
325 plan to extend the CEAP database and produce a multisector dataset in the near future.
326 Such a dataset can be used to identify the top polluting sources in China and to design
327 the corresponding policies for addressing the severe environmental pollution³⁷.

328

329 The CEAP database is subject to uncertainties and limitations. The CEMS network has
330 not covered all Chinese thermal power-generating units (with an average annual gap of
331 3.8% in unit capacity for 2014-2017), and these samples will be collected to update the
332 CEAP database in the future. The use of theoretical flue gas rates assumes a constant
333 boiler utilization rate and fuel requirement for each combination of fuel type, boiler
334 type and capacity scale. If it becomes available, future research can incorporate high-
335 frequency operational data (especially flue gas volume) for each unit to improve the
336 estimation accuracy. Uncertainty ranges of our estimates are estimated to be within
337 $\pm 9.03\%$ for emission factors and $\pm 2.47\%$ for total emissions, in terms of 2 standard
338 deviations. To enhance the reliability of CEMS data, the CEMS system can be verified
339 using aerial concentration measurements³¹, and the CEMS network can be subject to
340 independent audits such as those deployed in India³⁸. There is still large room to
341 improve the existing methods of detecting and processing outliers in CEMS data.

342

343 **Methods**

344 **Construction of the CEAP database.** The CEAP database uses systematic, detailed,
345 real-time monitoring data from China's CEMS network to estimate nationwide, unit-
346 based, time-varying emission factors and absolute emissions of SO₂, NO_x and PM (the
347 air pollutants covered by the new ULE standards) from Chinese power plants
348 (<http://www.ieimodel.org/>).

349

350 We have been granted exclusive access by the MEE to comprehensive nationwide data
351 from the Chinese CEMS network (<http://www.envsc.cn/>). In China, power plants
352 (including combined heat-and-power plants) operating coal-fired boilers with an output
353 above 65 tons of steam per hour (excluding stoker-fired boilers and spreader stoker-
354 fired boilers), pulverized coal-fired boilers, oil-fired boilers with an output above 65
355 tons per hour and gas turbines are required to install CEMS³⁹. The national CEMS
356 network covers most Chinese thermal (including fuel- and biomass-fired) power-
357 generating units and measures the emission concentrations of diverse air pollutants in
358 flue gas (g m⁻³) at power plant stacks. The monitoring data are collected in terms of
359 hourly averages and are further revised to the standard values based on a standard
360 oxygen level⁴⁰. In total, CEMS data involve 3,192, 3,527, 3,749 and 4,622 power plant
361 stacks for 2014, 2015, 2016 and 2017, respectively. In turn, these stacks are associated
362 with 5,248, 5,606 and 5,367 separate power-generating units and account for 96.01%,
363 97.15% and 95.91% of total thermal power capacity for 2014, 2015 and 2016,
364 respectively (Supplementary Data 2). For the small fraction of power-generating units
365 without CEMS, we assume that their polluting concentrations are at the average level
366 of units that have similar fuel types, that are located in the same region and that are
367 involved in the CEMS network. In some cases, several units share one smokestack, and
368 they are assumed to have similar stack concentrations.

369

370 The CEAP dataset also involves unit-specific information for each individual operating

371 unit for 2014-2016 regarding activity levels (such as fuel consumption and power
372 generation; yearly), fuel type, operating capacity, geographic location and pollution
373 control technology, and this information is similarly derived from the MEE. By
374 coupling this unit-specific information with CEMS data, we can detail the technologies
375 that were used to meet the ULE standards and the determinants (fuel, size, or region)
376 of early compliance. The CEAP database encompasses all thermal power-generating
377 units that burn coal, oil, natural gas, biomass and other fuels in 26 Chinese provinces
378 and 4 municipalities, excluding Tibet, Hong Kong, Macao and Taiwan (Supplementary
379 Data 5). In total, 5,943, 6,267, and 6,015 operating units (with total installed capacities
380 of 878,240, 958,308 and 983,857 MW) are involved for 2014, 2015 and 2016,
381 respectively (Supplementary Data 2).

382

383 **Preprocess of CEMS data.** Chinese government has made a great effort to regulate the
384 CEMS network and to ensure the reliability of CEMS data (Supplementary Note 5).
385 However, there still exist null observations and abnormal values (including zeroes
386 during operation and extreme values) in the CEMS dataset, which should be treated
387 carefully according to the related official regulations and guidelines. Plants report nulls
388 or zeroes during downtime for maintenance, such that we omit successive null- or zero-
389 value samples lasting for no less than 5 days (the shortest period of a maintenance
390 shutdown according to the regulation 41) in the estimation. Our estimates for downtime
391 are generally consistent with the official statistics that for a thermal power plant, the
392 downtime on average accounted for 19.45% of the time for 2015⁹ (17.11% in our
393 estimation). We treat missing data lasting for less than 5 days (representing 1.15%,
394 1.03%, 1.05% and 1.04% of total hours in 2014, 2015, 2016 and 2017, respectively) in
395 two different ways according to the guideline HJ/T 75-2007⁴²: we assume successive
396 missing data for above 24 hours during operation at similar levels to the points near the
397 time (in terms of monthly averages), and we set missing data lasting for 1-24 hour(s) to
398 the arithmetic mean of the two nearest valid values before and after.

399

400 We conducted a data preprocessing step that involved carefully reviewing each
401 observation via a data visualization and removing abnormal values, including the zeroes
402 during operation periods and the impossible values beyond the measurement ranges of
403 the CEMS monitors (Supplementary Data 6). The percentage of these abnormal values
404 is 0.18%, 0.10%, 0.04% and 0.03% for 2014, 2015, 2016 and 2017, respectively.
405 According to the regulation HJ/T 75-2007⁴², abnormal values in CEMS data should be
406 treated similarly to null observations. Missing data and abnormal data are not
407 considered a substantial problem, not only because they are only around 1% and 0.1%,
408 respectively, but also because their distributions are random, i.e., we do not observe a
409 higher occurrence of them in particular regions or times of the day/year. Accordingly,
410 we generate daily average stack concentrations by averaging the valid hourly
411 measurements (which are the resulting dataset after dealing with nulls, zeroes and
412 outliers) within the 24-h period and then generate monthly averages by averaging the
413 daily averages within the month³¹.

414

415 **Estimation of emission factors and absolute emissions.** The use of the CEMS
416 database offers a direct, simple estimation for nationwide, unit-based and time-varying
417 emission factors and absolute emissions of SO₂, NO_x and PM from Chinese thermal
418 power plants. This CEMS-based estimation method has two clear advantages over
419 traditional methods using average and invariable emission factors (Supplementary Note
420 1). First, the CEMS database provides direct, actual measurements, which avoids using
421 many indirect parameters and the associated assumptions and that were used in previous
422 studies and enhances the estimation accuracy. Second, the real-time CEMS data are
423 recorded at a high frequency (hourly), which improves the temporal resolutions of
424 emission factors (hourly; the smallest unit of CEMS data) and absolute emissions
425 (monthly; the smallest unit of activity data).

426

427 Based on CEMS stack concentration data, unit-level and hourly-frequency emission
428 factors for SO₂, NO_x and PM can be estimated by Eq. (1), without using the uncertain

429 parameters that are common in traditional methods (such as the pollutant content of the
430 fuel, the net heating value, the oxidation rate and the removal efficiency of control
431 technology)^{27,43}:

$$432 \quad EF_{s,i,y,m,h} = C_{s,i,y,m,h} V_{i,y}, \quad (1)$$

433 where the subscripts s and i indicate the emission species and unit, respectively; y , m
434 and h are the year, month and hour time indexes, respectively; EF represents the abated
435 emission factor, which is expressed as the mass of emitted pollutant per unit of fuel
436 consumption (g kg^{-1} for solid- or liquid-fired units and g m^{-3} for gas-fired units); C is
437 the stack concentration in flue gas based on a standard oxygen level (g m^{-3}), which is
438 available for 2014-2017 in the CEMS database; and V is the theoretical flue gas rate
439 (i.e., the flue gas volume per unit of fuel consumption in $\text{m}^3 \text{kg}^{-1}$ for solid- or liquid-
440 fired units and $\text{m}^3 \text{m}^{-3}$ for gas-fired units)^{44,45}. Because CEMS monitors are installed at
441 power plant stacks, abated emission concentrations after the effect of pollution control
442 technology (if available) are measured, and abated emission factors are estimated here
443 even without using the removal efficiency-related parameters.

444

445 Since the CEMS regulation mainly uses stack concentrations to evaluate the
446 performance of a power plant, a large fraction of other measurements (such as those for
447 flue gas volume) are missing in the CEMS dataset. Omitting these missing data will
448 lead to a substantial underestimation of the actual flue gas volume coming out of
449 China's thermal power plants⁴⁵. Therefore, we resort to theoretical flue gas rates in the
450 estimation⁴³, which are determined by fuel type, boiler type and installed capacity
451 according to the China Pollution Source Census (Supplementary Data 7)⁴⁴. Accordingly,
452 the actual volume of flue gas for each unit is calculated by multiplying the theoretical
453 flue gas rate by the actual fuel consumption. The use of theoretical flue gas rates to
454 estimate total pollutant emissions can avoid the impact of flue gas leakage, which is
455 known as a tough challenge in power plants and can largely distort the estimation for
456 flue gas volume⁴⁵.

457

458 The absolute SO₂, NO_x and PM emissions of each power-generating unit are estimated
459 by multiplying the activity data by the emission factors⁴⁶:

$$460 \quad E_{s,i,y,m} = A_{i,y,m} EF_{s,i,y,m}, \quad (2)$$

461 where E represents the unit-based emissions during power generation (g) and A is the
462 activity level, represented by the amount of fuel consumption (kg for solid- or liquid-
463 fired units and m³ for gas-fired units). In this study, power plant emissions are calculated
464 on a monthly basis. Notably, real-time CEMS data are hourly data, whereas the activity
465 data are annual for each unit, such that we need to use the monthly provincial thermal
466 power generation as a proxy to allocate the monthly unit-level fuel consumption (A)²⁶:

$$467 \quad A_{i,y,m} = \frac{F_{p_i,y,m}}{\sum_{m=1}^{12} F_{p_i,y,m}} A_{i,y}, \quad (3)$$

468 where p_i indicates the province of unit i and F is the provincial thermal power
469 generation available in the Chinese Energy Statistics Yearbooks⁴⁷. Monthly emission
470 factors are estimated by averaging hourly emission factors at the monthly scale.

471

472 The unit-specific activity data (A) are available only up to 2016 and are projected for
473 2017 according to the growth in provincial thermal power generation from 2016 to 2017.
474 This projection, however, assumes that the activity level of a power-generating unit
475 follows the overall development of provincial thermal power generation and that the
476 new units built in 2017 hold fuel type, installed capacity and region structures similar
477 to those of the existing units in 2016. With the assumption of homogenous growth rates
478 in power generation for different plants in a province, this method works well only in
479 places where marginal changes in demand lead to an increase in equal shares of supply
480 from all plants in a province. However, the electricity market reform⁴⁸ has changed this
481 since 2017 in the eight pilots, where spot electricity markets were introduced to
482 determine the shares of supply. Thus, the results for 2017 are associated with additional
483 uncertainties.

484

485 **Uncertainty analysis.** A series of uncertainty analyses are conducted to verify the

486 reliability of our estimates based on CEMS data. First, to address the uncertainty from
487 the volatility in high frequency CEMS data, statistical analysis is employed to fit the
488 probability distribution (in a normal form) of the stack concentrations of each emission
489 species by each power-generating unit in each month based on the associated daily
490 averages^{49,50}. For units without CEMS, a bootstrap simulation method is employed to
491 randomly select samples from units that have similar fuel types, that are located in the
492 same regions, and that are involved in the CEMS network at equal probabilities. A
493 Monte Carlo approach is employed to produce stack concentrations based on the
494 corresponding distributions, and 10,000 simulations are performed to assess the
495 uncertainty ranges of the estimated emission factors and absolute emissions^{27,43}. The
496 uncertainty analysis indicates that the uncertainty ranges in our estimates are relatively
497 small (with 2 standard deviations within $\pm 8.65\%$ for emission factors and $\pm 1.09\%$ for
498 absolute emissions; error bars in Figure 3).

499

500 Second, uncertainty might also arise from the use of theoretical flue gas rates due to the
501 technology, feedstock and other heterogeneities of power-generation units. Fortunately,
502 the CEMS database involves the measurements of flue gas rate for 1,516 units
503 (Supplementary Data 8), sufficing to generate a rough estimation of the likely ranges
504 of flue gas rates by fuel type, boiler type and unit capacity. The likely ranges are
505 estimated at a small level under the confidence level of 95% (with the maximal level of
506 $\pm 10\%$; Supplementary Data 7), finely supporting the use of theoretical flow rates. We
507 let the flue gas rate for every unit change randomly on the corresponding likely ranges
508 (for the types of units without flow rate samples, the largest likely range of $\pm 10.07\%$
509 estimated is used) by following a uniform distribution, and we run 10,000
510 simulations^{51,52}. We found that even with random variations, our estimates appear quite
511 robust (with 2 standard deviations within $\pm 9.03\%$ for emission factors and $\pm 2.47\%$ for
512 absolute emissions).

513

514 Third, we conduct an uncertainty analysis on the unit-specific activity data for 2017

515 (which are not yet available and are projected using a homogenous growth rate for a
516 province). The probability distribution of growth rates of activity level for each unit is
517 fitted in a normal form⁴³, based on a total of 10,000 samples that are randomly selected
518 by a bootstrap method from its previous values during 2014-2016. The heterogeneous
519 unit-level growth rates for different units from 2016 to 2017 are produced by a Monte
520 Carlo approach based on their own independent distributions and are then used to
521 allocate the total provincial growth to different units. Relying on 10,000 simulations,
522 the likely bound of total emissions for 2017 is estimated to $\pm 0.03\%$, in terms of 2
523 standard deviations.

524

525 **Estimation of future potential emission reductions.** Our estimation for the 2014-
526 2017 period reveals encouraging news about an overall early compliance of Chinese
527 coal-fired power plants with the ULE standards: the 2020 target (renovating a combined
528 580 million kW of the installed capacity of coal-fired units to meet the ULE standards)¹⁶
529 had been surpassed by 20 million kW by the end of 2017 (three years before the policy
530 implementation deadline of 2020), and the 2030 target (with 80% of coal-fired capacity
531 achieving compliance)¹⁷ was approached (72% in 2017). We then evaluate future
532 potential reductions under aggressive but feasible targets (considering the ever-
533 increasing stringency of air pollution standards in China in recent years). We consider
534 2020 as the target year because there is sufficient time (three years from 2018 to 2020)
535 left to accomplish tougher goals (in view of the satisfactory early compliance with
536 respect to the ULE standards). Moreover, China's 13th Five-Year Plan (2016-2020) for
537 Power Sector Development⁵³ provides predictions of the growth trends in the activity
538 levels of Chinese power plants.

539

540 To explore the potential reductions in power emissions under different ULE targets in
541 2020, we design 2 scenarios: we assume that all Chinese coal-fired capacity has been
542 retrofitted to meet the ULE limits by 2020; and we design an extreme case in which all
543 thermal power-generating units achieve ULE compliance in 2020. The activity levels

544 of different power-generating units in 2020 are projected according to China's 13th
545 Five-Year Plan (2016-2020) for Power Sector Development⁵³. The total power
546 generation in 2020 is assumed to meet the expected total power consumption (7.20
547 trillion kWh)⁵³ and is then allocated to different fuel types according to the planned
548 energy structure (with 31% of power generation from non-fossil-fired units⁵³ vs 100%-
549 31%=69% (4.97 trillion kWh) from fossil-fired units). For fossil-fired units, the power
550 generation from coal- and gas-fired units is assumed to follow the plans for the
551 respective total installed capacities (growing to 1.10 and 0.11 billion KW, respectively,
552 in 2020⁵³), reaching 4.59 and 0.30 trillion kWh, respectively, in 2020; thus, the power
553 generation from the other fossil-fired units is set to $4.97 - (4.59 + 0.30) = 0.08$ trillion kWh.
554 We assume that the new units built from 2017 to 2020 hold fuel type, installed capacity
555 and region structures similar to those of the existing units in 2016.

556

557 **Data availability**

558 The CEAP database that supports the findings of this study is available at
559 <http://www.ieimodel.org/>. Supplementary Data 2 presents a summary of the CEAP
560 dataset. The data regarding the compilation of the CEAP dataset include CEMS data
561 collected from the platforms listed in Supplementary Data 9, and the unit-specific
562 information provided in Supplementary Data 10. The data regarding the estimation of
563 emission factors and absolute emissions include the stack concentrations presented in
564 Figure 1, Supplementary Figures 1-3 and Supplementary Data 3, the flue gas rates
565 provided in Supplementary Data 7 and 8, and the unit information provided in
566 Supplementary Data 10 and 11. The data regarding the analysis of the determinants of
567 early ULE compliance (region, fuel and capacity) are presented in Supplementary
568 Figures 4-9.

569

570 **Code availability**

571 All computer codes generated during this study are available from the corresponding
572 authors upon reasonable request.

574 **References**

- 575 1. Health Effects Institute. *State of Global Air 2019*. Special Report. (Boston, MA: Health Effects
576 Institute, 2018).
- 577 2. World Bank and Institute for Health Metrics and Evaluation. *The cost of air pollution:
578 Strengthening the economic case for action*. (Washington, DC: World Bank, 2016).
- 579 3. Zhang, Q., He, K. & Huo, H. Cleaning China's air. *Nature* **484**, 161-162 (2012).
- 580 4. Zhao, Y., Zhang, J. & Nielsen, C.P. The effects of recent control policies on trends in emissions
581 of anthropogenic atmospheric pollutants and CO₂ in China. *Atmos. Chem. Phys. Discuss.* **12**(9),
582 24985-25036 (2012).
- 583 5. Zheng, B. et al. Trends in China's anthropogenic emissions since 2010 as the consequence of
584 clean air actions. *Atmos. Chem. Phys.* **18**(19), 14095-14111(2018).
- 585 6. Klimont, Z. et al. Global anthropogenic emissions of particulate matter including black carbon.
586 *Atmos. Chem. Phys.* **17**(14), 8681-8723 (2017).
- 587 7. Lu, Z., Zhang, Q. & Streets, D.G. Sulfur dioxide and primary carbonaceous aerosol emissions
588 in China and India, 1996-2010. *Atmos. Chem. Phys.* **11**(18), 9839-9864 (2011).
- 589 8. Li, M. et al. MIX: A mosaic Asian anthropogenic emission inventory under the international
590 collaboration framework of the MICS-Asia and HTAP. *Atmos. Chem. Phys.* **17**(23), 34813-
591 34869 (2017).
- 592 9. Ministry of Ecology and Environment of the People's Republic of China. *China Environmental
593 Statistics Yearbooks 2010-2015* (China Environmental Press, 2010-2015).
- 594 10. Xia, Y., Zhao, Y. & Nielsen, C.P. Benefits of China's efforts in gaseous pollutant control
595 indicated by the bottom-up emissions and satellite observations 2000–2014. *Atmos.
596 Environ.* **136**, 43-53 (2016).
- 597 11. Zhao, B. et al. NO_x emissions in China: Historical trends and future perspectives. *Atmos. Chem.
598 Phys.* **13**(19), 9869-9897 (2013).
- 599 12. Huang, R. et al. High secondary aerosol contribution to particulate pollution during haze events
600 in China. *Nature* **514**, 218-222 (2014).
- 601 13. Ministry of Ecology and Environment of the People's Republic of China. *Emission Standard
602 of Air Pollutants for Thermal Power Plants (GB13223-2011)* (China Environmental Press,
603 2011). (*in Chinese*)
- 604 14. National Development and Reform Commission, Ministry of Ecology and Environment of the
605 People's Republic of China & National Energy Administration. *Upgrade and Retrofit Plan for
606 Coal-fired Power Plants Aiming at Energy Savings and Emissions Reduction for 2014-2020*
607 (National Development and Reform Commission, 2014). (*in Chinese*)
- 608 15. Ministry of Ecology and Environment of the People's Republic of China. *Guideline on
609 Available Technologies of Pollution Prevention and Control for Thermal Power Plant* (China
610 Environmental Science Press, 2017).
- 611 16. Ministry of Ecology and Environment of the People's Republic of China, National
612 Development and Reform Commission & National Energy Administration. *Work Plan of Full
613 Implementing Ultra-low Emission Policy and Energy Saving Transformation for Coal-fired
614 Power Plants* (Ministry of Ecology and Environment of the People's Republic of China, 2015).
615 (*in Chinese*)

- 616 17. National Development and Reform Commission & National Energy Administration.
617 *Revolutionary Strategy for Energy Production and Consumption (2016-2030)* (National
618 Development and Reform Commission, 2016). (in Chinese)
- 619 18. Gao, J. et al. Improving air pollution control policy in China—A perspective based on cost-
620 benefit analysis. *Sci. Total Environ.* **543**, 307-314 (2016).
- 621 19. China's Energy Administration. *Action Plan for Clean and Efficient Use of Coal (2015-2020)*
622 (China's Energy Administration, 2015). (in Chinese)
- 623 20. Yang, H. et al. Cost estimate of the multi-pollutant abatement in coal-fired power sector in
624 China. *Energy* **161**, 523-535 (2018).
- 625 21. Wang, C., Olsson, G. & Liu, Y. Coal-fired power industry water-energy-emission nexus: A
626 multi-objective optimization. *J. Clean. Prod.* **203**, 367-375 (2018).
- 627 22. Ni, Z. et al. Potential air quality improvements from ultralow emissions at coal-fired power
628 plants in China. *Aerosol. Air. Qual. Res.* **18**, 1944-1951 (2018).
- 629 23. Lin, C. et al. A global perspective on sulfur oxide controls in coal-fired power plants and
630 cardiovascular disease. *Scientific Reports* **8**(1), 2611 (2018).
- 631 24. Li, M. & Patiño-Echeverri, D. Estimating benefits and costs of policies proposed in the 13th
632 FYP to improve energy efficiency and reduce air emissions of China's electric power sector.
633 *Energy Policy* **111**, 222-234 (2017).
- 634 25. Tong, D. et al. Targeted emission reductions from global super-polluting power plant units.
635 *Nature Sustainability* **1**(1), 59-68 (2018).
- 636 26. Liu, F. et al. High-resolution inventory of technologies, activities, and emissions of coal-fired
637 power plants in China from 1990 to 2010. *Atmos. Chem. Phys.* **15**(23), 13299-13317 (2015).
- 638 27. Chen, L. et al. Unit-based emission inventory and uncertainty assessment of coal-fired power
639 plants. *Atmos. Environ.* **99**, 527-535 (2014).
- 640 28. Zhao, Y. et al. Primary air pollutant emissions of coal-fired power plants in China: Current
641 status and future prediction. *Atmos. Environ.* **42**(36), 8442-8452 (2008).
- 642 29. Wang, S. et al. Growth in NO_x emissions from power plants in China: Bottom-up estimates
643 and satellite observations. *Atmos. Chem. Phys.* **12**(10), 4429-4447 (2012).
- 644 30. Tian, H. et al. Nitrogen oxides emissions from thermal power plants in china: Current status
645 and future predictions. *Environ. Sci. Technol.* **47**(19), 11350-11357 (2013).
- 646 31. Karplus, V.J., Zhang, S. & Almond, D. Quantifying coal power plant responses to tighter SO₂
647 emissions standards in China. *Proc. Natl Acad. Sci. USA* **115**(27), 7004-7009 (2018).
- 648 32. National People's Congress of the People's Republic of China. *Environmental Protection Tax*
649 *Law* (National People's Congress of the People's Republic of China, 2016). (in Chinese)
- 650 33. Sui, Z. et al. Fine particulate matter emission and size distribution characteristics in an ultra-
651 low emission power plant. *Fuel* **185**, 863-871 (2018).
- 652 34. China Electricity Council. *China Power Industry Annual Development Report 2015-2018*
653 (China Market Press, 2015-2018).
- 654 35. Driscoll, C.T. et al. US power plant carbon standards and clean air and health co-benefits. *Nat.*
655 *Clim. Chang.* **5**(6), 535-540 (2015).
- 656 36. Bo, X. et al. Aviation's emissions and contribution to the air quality in China. *Atmos.*
657 *Environ.* **201**, 121-131 (2019).
- 658 37. Yuan, X., Zhang, M., Wang, Q., Wang, Y. & Zuo, J. Evolution analysis of environmental
659 standards: Effectiveness on air pollutant emissions reduction. *J. Clean. Prod.* **149**, 511-520

- 660 (2017).
- 661 38. Duflo, E., Greenstone, M., Pande, R. & Ryan, N. Truth-telling by third-party auditors and the
662 response of polluting firms: Experimental evidence from India. *Q. J. of Econ.* **128**(4), 1499-
663 1545 (2013).
- 664 39. Ministry of Ecology and Environment of the People's Republic of China. *Emission Standard*
665 *of Air Pollutants for Thermal Power Plants (GB13223-2003)* (China Environmental Press,
666 2003). (in Chinese)
- 667 40. Ministry of Ecology and Environment of the People's Republic of China. *Emission Standard*
668 *of Air Pollutants for Thermal Power Plants (GB13223-1996)* (China Environmental Press,
669 1996). (in Chinese)
- 670 41. Ministry of Commerce of the People's Republic of China. *Guide of Maintenance for Power*
671 *Plant Equipment* (Ministry of Commerce of the People's Republic of China, 2003). (in
672 Chinese)
- 673 42. Ministry of Ecology and Environment of the People's Republic of China. *Specifications for*
674 *Continuous Emissions Monitoring of Flue Gas Emitted from Stationary Sources (HJ/T 75-2007)*
675 (Ministry of Ecology and Environment of the People's Republic of China, 2007). (in Chinese)
- 676 43. Zhao, Y. et al. Establishment of a database of emission factors for atmospheric pollutants from
677 Chinese coal-fired power plants. *Atmos. Environ.* **44**(12), 1515-1523 (2010).
- 678 44. China Pollution Source Census. *Manual of the First National Pollution Source Census on*
679 *Emission Factors from Industrial Pollution Sources.* (China Environmental Science Press,
680 2011) (in Chinese)
- 681 45. Gilbert, A.Q. & Sovacool, B.K. Benchmarking natural gas and coal-fired electricity generation
682 in the United States. *Energy* **134**, 622-628 (2017).
- 683 46. Liu, Z. et al. Reduced carbon emission estimates from fossil fuel combustion and cement
684 production in China. *Nature* **524**, 335-338 (2015).
- 685 47. National Bureau of Statistics. *China Energy Statistics Yearbook* (China Statistics Press, 2017).
686 (in Chinese)
- 687 48. National Development and Reform Commission & National Energy Administration. *Notice of*
688 *Implementing Pilots for Spot Electricity Market.* (National Development and Reform
689 Commission, 2017). (in Chinese)
- 690 49. Frey, H.C. & Zheng, J. Quantification of variability and uncertainty in air pollutant emission
691 inventories: method and case study for utility NO_x emissions. *J. Air Waste Manag. Assoc.* **52**(9),
692 1083-1095 (2002).
- 693 50. Streets, D. et al. An inventory of gaseous and primary aerosol emissions in Asia in the year
694 2000. *J. Geophys. Res. Atmos.* **108**(D21), 1984-2012 (2003).
- 695 51. Tang, L., Wu, J., Yu, L. & Bao, Q. Carbon emissions trading scheme exploration in China: A
696 multi-agent-based model. *Energy Policy* **81**, 152-169 (2015).
- 697 52. Zhao, Y., Nielsen, C.P., Lei, Y., McElroy, M.B. & Hao, J. Quantifying the uncertainties of a
698 bottom-up emission inventory of anthropogenic atmospheric pollutants in China. *Atmos. Chem.*
699 *Phys.* **11**(5), 2295-2308 (2011).
- 700 53. National Development and Reform Commission & National Energy Administration. *The*
701 *Power Sector Development during the 13th Five-Year-Plan (2016-2020)* (National
702 Development and Reform Commission, 2017). (in Chinese)
- 703

704 **Additional information**

705 **Correspondence and requests for materials** should be addressed to Z.M. or X.B.

706

707 **Acknowledgements**

708 This work was supported by the grants from the National Science Foundation for

709 Outstanding Young Scholars (71622011), the National Program for Support of Top

710 Notch Young Professionals and the National Research Program for Key Issues in Air

711 Pollution Control (DQGG-05-07).

712

713 **Author contributions**

714 L.T., Z.M., X.B. and S.W. designed the research. X.B., S.L. and X.Z. processed and

715 analysed the data of Continuous Emission Monitoring Systems. X.W. compiled and

716 analysed the unit-specific information for Chinese power plants. L.T., J.Q., X.C. and


717 X.X. conducted the experimental work. L.T., Z.M. and L.D.A. wrote the paper. All

718 authors contributed to developing and writing the manuscript.

719

720 **Competing interests**

721 The authors declare no financial or non-financial competing interests.



722

723 **Figure 1 | Chinese power plant stacks with continuous emissions monitoring**

724 **systems in 2017. a,** Locations, fuel types and combined capacities of the involved

725 generating units totalling 4,622 power plant stacks nationwide. In turn, these stacks

726 consist of 1,501 thermal (including fossil fuel- and biomass-burning) power plants or

727 5,367 power-generating units, with a combined installed capacity of 943.60 GW, i.e.,

728 95.91% of total thermal power capacity in 2017. The stacks are classified by fuel type

729 and combined capacity of the associated units. The inset at the lower right corner shows

730 islands in the South China Sea, for which there is no data. **b-d,** Histograms of annual


731 average concentrations in 2017 of SO₂ (**b**), NO_x (**c**) and PM (**d**) for different thermal

732 power plant stacks. The red dashed lines show the ultra-low emissions standards, the

733 dashed lines in different non-red colours indicate the mean for different years, and the

734 shading represents the 90% and 95% intervals.

735



736

737 **Figure 2 | Daily distributions of stack concentrations at Chinese power plant stacks**

738 **2014-2017. a-o,** Distributions of daily average stack concentrations of all Chinese


739 power plant stacks (a-c) and those associated with coal- (d-f), gas and oil- (g-i),

740 biomass- (j-l) and other fuels-fired units (m-o) for SO₂ (a, d, g, j and m), NO_x (b, e, h,

741 k and n) and PM (c, f, i, l and o). The red dashed horizontal lines show the ultra-low

742 emission standards, the black dashed vertical lines mark September 12, 2014 when the


743 ultra-low emissions standards were introduced, the black full lines indicate the mean,
 744 and the shading shows the intervals of percentiles. The insets in the 2nd row show the
 745 mean of preexisting units built before 2015 (blue lines) and new units built after 2015
 746 (green lines).
 747



749 **Figure 3 | Monthly emission factors and total emissions for Chinese power-**
 750 **generating units 2014-2017. a-c,** Emission factors for coal- and biomass-fired units (g
 751 kg⁻¹; left axis) and gas-fired units (g m⁻³; right axis) for SO₂ (a), NO_x (b) and PM (c).
 752 The dashed vertical lines mark September 12, 2014 when the ultra-low emissions
 753 standards were introduced. **d-f,** Estimated total power emissions (10 kt per month; left
 754 axis) for SO₂ (d), NO_x (e) and PM (f), together with total thermal power generation
 755 (TWh; right axis). The 2 sigma for the error bars means the 2 standard deviations. The
 756 datapoints in panels **d**, **e** and **f** are from Refs. 5, 8, 10, 11 and 30, and the Greenhouse
 757 Gas and Air Pollution Interactions and Synergies database (GAINS)
 758 (https://gains.iiasa.ac.at/models/gains_models3.html) and Multi-resolution Emission
 759 Inventory for China (MEIC) (<http://meicmodel.org/>). The percentages reflect the
 760 percentage reduction of our current estimates (dashed horizontal lines) relative to the

761 corresponding previous estimates (discrete datapoints).

762



763

764 **Figure 4 | Absolute emission reductions for 2014-2020.** a-i, Estimated reductions in
 765 SO₂, NO_x and PM emissions from the power-generating units classified by fuel type
 766 (a-c), region (d-f) and capacity (g-i). The bars in blueish grey show the estimated annual
 767 power emissions, and the bars in bright colours represent the emission reductions of the
 768 associated unit categories. Absolute emission reductions from all units across years are
 769 shown in *x* axis. The results for 2017-2020 are projected based on China's 13th Five-
 770 Year Plan (2016-2020) for Power Sector Development⁵³ and the assumption that all
 771 units meet the ultra-low emissions standards in 2020 in the same way (using the same
 772 technologies and upgrades) as those used to meet the standards during 2014-2017.